DOOR AND WINDOW SCHEDULE						
SR. NO.	TYPE	WIDTH (mm)	HEIGHT (mm)	SILL LVL	UNTIL LVL	TYPE
1	D1	900	2100	0	2100	UPVC
2	D2	750	2100	0	2100	UPVC
3	D3	1000	2100	0	2100	UPVC
4	D3a	1000	2100	0	2100	UPVC
5	D4	800	2100	0	2100	UPVC
6	D5	1800	2400		2400	UPVC
7	D6	1100	2350	50	2400	UPVC
8	SD1	2500	2600	0	2600	UPVC
9	SD2	1700	2600	0	2600	UPVC
10	SD4	3100	2600	0	2600	UPVC
11	SD5	2100	2600	0	2600	UPVC
12	SD6	4200	2600	0	2600	UPVC
13	SD7	2500	2600	0	2600	UPVC
14	SD8	2450	2600	0	2600	UPVC
15	SD9	3000	2600	0	2600	UPVC
16	DW1	1500	1550	1050	2600	UPVC
17	DW2	2300	2600	0	2600	UPVC
18	DW3	3000	5000	0	5000	UPVC
19	DW4	3000	5000	0	5000	UPVC
20	DW5	4000	5000	0	5000	UPVC
21	DW6	3900	5000	0	5000	UPVC
22	W1	750	1550	1050	2600	UPVC
23	W2	600	1550	1050	2600	UPVC
24	W3	700	1550	1050	2600	UPVC
25	W4	1100	1550	1050	2600	UPVC
26	W5	1200	1550	1050	2600	UPVC
27	W6	1700	1550	1050	2600	UPVC
28	W8	3200	1200	1050	2400	UPVC
29	FD	1200	2400	0	2400	2HR FIRE RATED
30	FDa	1200	2400	0	2400	2HR FIRE RATED
31	FD1	900	2400	0	2400	2HR FIRE RATED
32	FD2	1500	2400	0	2400	2HR FIRE RATED
33	FD3	1000	2400	0	2400	2HR FIRE RATED
34	FD4	750	2350	50	2400	2HR FIRE RATED
35	FD5	1000	2350	50	2400	2HR FIRE RATED
36	FD6	1100	2350	50	2400	2HR FIRE RATED
37	FD7	2000	2700		2700	2HR FIRE RATED
38	FD8	1200	2100		2100	2HR FIRE RATED
39	FD10	2400	2400		2400	2HR FIRE RATED
40	FD11	1700	2400			2HR FIRE RATED
41	GL	3000	5000	0	5000	UPVC
42	GL1	1600	5000	0	5000	UPVC

DIMENSION LEGEND:
- (RSR) ARCHITECTURE DIM.
- (RSR) AREA DIM.

LEGEND :-

	1	160 OD uPVC SWR CLASS B SOIL & WASTE D/T PIPE
	1a	110 OD uPVC SWR CLASS B SOIL D/T PIPE
	2	110 OD uPVC SWR CLASS B WASTE D/T PIPE
	3	110 OD uPVC SWR CLASS B ANTISYPHONIC PIPE
	4	160 OD uPVC SWR CLASS B KITCHEN WASTE PIPE
	5	160 OD uPVC SWR CLASS B RAIN WATER DOWNTAKE PIPE
	6	DOMESTIC WATER SUPPLY DOWNTAKE PIPE (GI CLASS C)
	7	FLUSHING WATER SUPPLY DOWNTAKE PIPE (GI CLASS C)
	8	110 OD uPVC SWR CLASS B BALCONY DRAIN PIPE
	9	1100 uPVC SWR CLASS B CONDENSATE DRAIN PIPE
	10	HOT WATER SUPPLY (GI CLASS C) DOWNTAKE PIPE FROM SOLAR
	N.T.	NAHANI TRAP (50mm WATER SEALED)
	M.N.T.	MULTI NAHANI TRAP (50mm WATER SEALED)
	A	110 OD uPVC SWR CLASS B SOIL PIPE
	B	110 OD uPVC SWR CLASS B WASTE PIPE
	C	50 OD uPVC SWR CLASS B WASTE PIPE
	D	40 OD uPVC SWR CLASS B KITCHEN SINK & WASH BASIN OUTLET PIPE
	E	63/75 OD uPVC SWR CLASS B WASTE PIPE

FIRE FIGHTING BLOCKS & ABBREVIATION

BLOCK	BLOCK TYPE
	PENDENT SPRINKLER
	UP-RIGHT SPRINKLER
	DELUGE WATER CURTAIN NOZZLE
	SIDE WALL SPRINKLER
	FIRE HOSE CABINET
	ICV-ISOLATION CONTROL VALVE
	FLOW SWITCH
	4.5 KG CO2 TYPE FIRE EXTINGUISHER
	6 KG ABC TYPE FIRE EXTINGUISHER
	FHC FLOOR DRAIN

PLUMBING LEGEND
- (A) 100# C.I. PARKING DRAIN PIPE
- (D) 100# C.I. PARKING DRAIN POINT



TYPICAL SECTIONAL DETAIL OF PARKING DRAIN PIPE





Note :-

1. BUILDING WILL BE DESIGNED (STRUCTURES) AS PER RELEVANT IS CODES FOR EARTH QUAKE RESISTANCE.

PLOT BOUNDARY

ZONING SETBACK

PROJECT

REVISED (1ST REVISION) BUILDING PLANS OF PHASE-VI (PRIVANA-WEST) FALLING UNDER RESIDENTIAL COLONY UNDER NEW INTEGRATED LICENSING POLICY(NILP) DATED 11.05.2022 ON LAND MEASURING 116.29625 ACRES (LICENCE NO. 219 OF 2023.DATED 25-10-23.) (AN AREA MEASURING 103.05625 ACRES MIGRATION FROM LICENCE NO. 27 OF 2012 DATED 02.04.2012 AND 13.24 ACRES AS FRESH AS FRESH APPLIED AREA) IN SECTOR -76 & 77, GURUGRAM MANESAR URBAN COMPLEX BEING DEVELOPED BY DLF LTD.IN COLLABORATION WITH LAND OWNERS AND IT`S ASSOCIATE COMPANIES

DESIGN ARCHITECT

ARCHITECTS:-
DESIGN FORUM INTERNATIONAL
Address : K-47 , KAILASH COLONY , NEW DELHI -48
Phone : 011-46556600,46556601 , FAX - 46556601
Website: www.designforuminternational.com

ASSOCIATE ARCHITECTS

RSMS ARCHITECTS
RSMS ARCHITECTS PVT. LTD.
69,Nora Niwas Bhawani Kunj
(Behind D2), Vasant Kunj,
New Delhi-110070.
Tel.: 011-26898616,26898617
www.rsms-arch.com

This is a "PROVISIONAL BUILDING PLAN" approved only for the purpose of inviting Objections from the general public

S.T.P.(HQ) Member Secretary B.P.A.C. | S.T.P.(G) Member B.P.A.C. | S.T.P.(HR.) Chairman B.P.A.C.

DTP(HQ) JD. | ATP(HQ) P.A. | A.T.P. | DINESH KUMAR PA(HQ)

JTP(HQ) Manager

TO BE READ WITH THIS OFFICE MEMO NO.:- 43791 DATED:- 19/11/2024

ARCHITECT'S SEAL & SIGNATURE	OWNER'S SEAL & SIGNATURE
CHANCHAL JAIN (REGISTERED ARCHITECT) CA/2005/36771	DLF Limited Authorised Signatory

Checked and found ok for Public Health (Internal) Service only subject to comments in in forwarding letter No. 365208 Dt. 24/12/2024

Executive Engineer (HQ)
For Executive Engineer
HSVP, Panchkula

BASEMENT-3	
TYPES OF PARKING	COUNT
NORMAL PARKING	839
HANDICAP PARKING	10
TOTAL PARKING	849
ESC	854

JAN.-2025	Scale :- 1:300	NORTH	
Drawing Title:- BASEMENT PLAN-03		Drawing No:- BS-03	
		03012025	

BASEMENT-03
LVL.-12100